



cfo-bmc@gujarat.gov.in



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOBMC/2021/00000364
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOBMC/2021/00000364/R1

Date: 08/11/2024

Building Occupancy/Category: Educational (non-residential)

To,

VASAYA GULAMABBAS YUSUFALI
541/AB SHSHUVIHAR CIRCLE BHAVNAGAR Bhavnagar MC 364001
Fire Region: Bhavnagar MC
Mobile No: 9924984005 Email ID: almahdi14@rediffmail.com

This has reference to your Application No. **2024/00095080** dated 06/11/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise **ALMAHDI FOUNDATION TRUST SANCHALIT MAHDI SCHOOL** (name of the Building/Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: BHAVNAGAR
5. Name of Block(s): ALMAHDI FOUNDATION TRUST SANCHALIT MAHDI SCHOOL

The building/premise was inspected on **08/11/2024** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **08/11/2024**
2. Six monthly inspection was done on **08/11/2024**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **15/11/2026** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Jay Vahanka
Fire Safety Officer - Advance (FSO-A)
2021/000131

Date: 08/11/2024
Time: 07:37 PM



FSCA/O/CFOBMC/2021/00000364/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.

Principal Mahdi English School Bhavnagar

PRINCIPAL
MAHDI ENGLISH SCHOOL
BHAVNAGAR

Manager Mahdi English School Bhavnagar

MANAGER
MAHDI ENGLISH SCHOOL
BHAVNAGAR